

CHAPTER 14

MEDIUM- AND HIGH-TEMPERATURE WATER HEATING SYSTEMS

System Characteristics	14.1	Air Heating Coils	14.8
Basic System	14.2	Space Heating Equipment	14.8
Design Considerations	14.2	Instrumentation and Controls	14.8
Distribution Piping		Water Treatment	14.9
Design	14.7	Heat Storage	14.9
Heat Exchangers	14.8	Safety Considerations	14.9

MEDIUM-TEMPERATURE water systems have operating temperatures below 350°F and permit design to a pressure rating of 125 to 150 psig. High-temperature water systems are classified as those operating with supply water temperatures above 350°F and designed to a pressure rating of 300 psig. The usual practical temperature limit is about 450°F because of pressure limitations on pipe fittings, equipment, and accessories. The rapid pressure rise that occurs as the temperature rises above 450°F increases cost because components rated for higher pressures are required (see [Figure 1](#)). The design principles for both medium- and high-temperature systems are basically the same. In this chapter, “high-temperature water” (HTW) refers to both systems.

This chapter presents the general principles and practices that apply to HTW and distinguishes them from low-temperature water systems operating below 250°F. See [Chapter 12](#) for basic design considerations applicable to all hot-water systems.

SYSTEM CHARACTERISTICS

The following characteristics distinguish HTW systems from steam distribution or low-temperature water systems:

- The system is a completely closed circuit with supply and return mains maintained under pressure. There are no losses from flashing, and heat that is not used in the terminal heat transfer equipment is returned to the HTW generator. Tight systems have minimal corrosion.
- Mechanical equipment that does not control performance of individual terminal units is concentrated at the central station.
- Piping can slope up or down or run at a variety of elevations to suit the terrain and the architectural and structural requirements without provision for trapping at each low point. This may reduce the amount of excavation required and eliminate drip points and return pumps required with steam.
- Greater temperature drops are used and less water is circulated than in low-temperature water systems.
- The pressure in any part of the system must always be well above the pressure corresponding to the temperature at saturation in the system to prevent the water flashing into steam.
- Terminal units requiring different water temperatures can be served at their required temperatures by regulating the flow of water, modulating water supply temperature, placing some units in series, and using heat exchangers or other methods.
- The high heat content of the water in the HTW circuit acts as a thermal flywheel, evening out fluctuations in the load. The heat storage capacity can be further increased by adding heat storage tanks or by increasing the temperature in the return mains during periods of light load.
- The high heat content of the heat carrier makes high-temperature water unsuitable for two-pipe dual-temperature (hot and chilled water) applications and for intermittent operation if rapid start-up and shutdown are desired, unless the system is designed for minimum water volume and is operated with rapid response controls.
- Higher engineering skills are required to design a HTW system that is simple, yet safer and more convenient to operate than are required to design a comparable steam or low-temperature water system.
- HTW system design requires careful attention to basic laws of chemistry and physics as these systems are less forgiving than standard hydronic systems.




Fig. 1 Relation of Saturation Pressure and Enthalpy to Water Temperature

The preparation of this chapter is assigned to TC 6.1, Hydronic and Steam Equipment and Systems.




Fig. 2 Elements of High-Temperature Water System

BASIC SYSTEM

HTW systems are similar to conventional forced hot-water heating systems. They require a heat source (which can be a direct-fired HTW generator, a steam boiler, or an open or closed heat exchanger) to heat the water. The expansion of the heated water is usually taken up in an expansion vessel, which simultaneously pressurizes the system. Heat transport depends on circulating pumps. The distribution system is closed, comprising supply and return pipes under the same basic pressure. Heat emission at the terminal unit is indirect by heat transfer through heat transfer surfaces. The basic system is shown in Figure 2.

The main differences of HTW systems from low-temperature water systems are the higher pressure, heavier equipment, generally smaller pipe sizes, and manner in which water pressure is maintained.

Most systems are either (1) a saturated steam cushion system, in which the high-temperature water develops its own pressure, or (2) a gas- or pump-pressurized system, in which the pressure is imposed externally.

HTW generators and all auxiliaries (such as water makeup and feed equipment, pressure tanks, and circulating pumps) are usually located in a central station. Cascade HTW generators sometimes use an existing steam distribution system and are installed remote from the central plant.

DESIGN CONSIDERATIONS

Selection of the system pressure, supply temperature, temperature drop, type of HTW generator, and pressurization method are the most important initial design considerations. The following are some of the determining factors:

- Type of load (space heating and/or process); load fluctuations during a 24 h period and a 1 year period. Process loads might require water at a given minimum supply temperature continuously, whereas space heating can permit temperature modulation as a function of outdoor temperature or other climatic influences.
- Terminal unit temperature requirements.
- Distance between heating plant and space or process requiring heat.
- Quantity and pressure of steam used for power equipment in the central plant.
- Elevation variations within the system and the effect of basic pressure distribution.

Usually, distribution piping is the major investment in an HTW system. A distribution system with the widest temperature spread (Δt) between supply and return will have the lowest initial and operating costs. Economical designs have a Δt of 150°F or higher.

The requirements of terminal equipment or user systems determine the system selected. For example, if the users are 10 psig steam generators, the return temperatures would be 250°F. A 300 psig rated

system operated at 400°F would be selected to serve the load. In another example, where the primary system serves predominantly 140 to 180°F hot-water heating systems, an HTW system that operates at 325°F could be selected. The supply temperature is reduced by blending with 140°F return water to the desired 180°F hot water supply temperature in a direct-connected hot-water secondary system. This highly economical design has a 140°F return temperature in the primary water system and a Δt of 185°F.

Because the danger of water hammer is always present when the pressure drops to the point at which pressurized hot water flashes to steam, the primary HTW system should be designed with steel valves and fittings of 150 psi. The secondary water, which operates below 212°F and is not subject to flashing and water hammer, can be designed for 125 psi and standard HVAC equipment.

Theoretically, water temperatures up to about 350°F can be provided using equipment suitable for 125 psi. But in practice, unless push-pull pumping is used, maximum water temperatures are limited by the system design, pump pressures, and elevation characteristics to values between 300 and 325°F.

Many systems designed for self-generated steam pressurization have a steam drum through which the entire flow is taken, and which also serves as an expansion vessel. A circulating pump in the supply line takes water from the tank. The temperature of the water from the steam drum cannot exceed the steam temperature in the drum that corresponds to its pressure at saturation. The point of maximum pressure is at the discharge of the circulating pump. If, for example, this pressure is to be maintained below 125 psig, the pressure in the drum that corresponds to the water temperature cannot exceed 125 psig minus the sum of the pump pressure and the pressure that is caused by the difference in elevation between the drum and the circulating pump.

Most systems are designed for inert gas pressurization. In most of these systems, the pressurizing tank is connected to the system by a single balance line on the suction side of the circulating pump. The circulating pump is located at the inlet side of the HTW generator. There is no flow through the pressurizing tank, and a reduced temperature will normally establish itself inside. A special characteristic of a gas-pressurized system is the apparatus that creates and maintains gas pressure inside the tank.

In designing and operating an HTW system, it is important to maintain a pressure that always exceeds the vapor pressure of the water, even if the system is not operating. This may require limiting the water temperature and thereby the vapor pressure, or increasing the imposed pressure.

Elevation and the pressures required to prevent water from flashing into steam in the supply system can also limit the maximum water temperature that may be used and must therefore be studied in evaluating the temperature-pressure relationships and method of pressurizing the system.

The properties of water that govern design are as follows:

- Temperature versus pressure at saturation (Figure 1)
- Density or specific volume versus temperature
- Enthalpy or sensible heat versus temperature
- Viscosity versus temperature
- Type and amount of pressurization

The relationships among temperature, pressure, specific volume, and enthalpy are all available in steam tables. Some properties of water are summarized in Table 1 and Figure 3.

Direct-Fired High-Temperature Water Generators

In direct-fired HTW generators, the central stations are comparable to steam boiler plants operating within the same pressure range. The generators should be selected for size and type in keeping with the load and design pressures, as well as the circulation requirements peculiar to high-temperature water. In some systems, both steam for power or processing and high-temperature water are

Table 1 Properties of Water, 212 to 400°F

Temperature, °F	Absolute Pressure, psia*	Density, lb/ft ³	Specific Heat, Btu/lb·°F	Total Heat above 32°F		Dynamic Viscosity, Centipoise
				Btu/lb*	Btu/ft ³	
212	14.70	59.81	1.007	180.07	10,770	0.2838
220	17.19	59.63	1.009	188.13	11,216	0.2712
230	20.78	59.38	1.010	198.23	11,770	0.2567
240	24.97	59.10	1.012	208.34	12,313	0.2436
250	29.83	58.82	1.015	218.48	12,851	0.2317
260	35.43	58.51	1.017	228.64	13,378	0.2207
270	41.86	58.24	1.020	238.84	13,910	0.2107
280	49.20	57.94	1.022	249.06	14,430	0.2015
290	57.56	57.64	1.025	259.31	14,947	0.1930
300	67.01	57.31	1.032	269.59	15,450	0.1852
310	77.68	56.98	1.035	279.92	15,950	0.1779
320	89.66	56.66	1.040	290.28	16,437	0.1712
330	103.06	56.31	1.042	300.68	16,931	0.1649
340	118.01	55.96	1.047	311.13	17,409	0.1591
350	134.63	55.59	1.052	321.63	17,879	0.1536
360	153.04	55.22	1.057	332.18	18,343	0.1484
370	173.37	54.85	1.062	342.79	18,802	0.1436
380	195.77	54.47	1.070	353.45	19,252	0.1391
390	220.37	54.05	1.077	364.17	19,681	0.1349
400	247.31	53.65	1.085	374.97	20,117	0.1308

*Source: *Thermodynamic Properties of Steam*, J.H. Keenan and F.G. Keyes, John Wiley & Sons, 1936 edition.




Fig. 3 Density and Specific Heat of Water

supplied from the same boiler; in others, steam is produced in the boilers and used for generating high-temperature water; and in many others, the burning fuel directly heats the water.

HTW generators can be the water-tube or fire-tube type, and can be equipped with any conventional fuel-firing apparatus. Water-tube generators can have either forced circulation, gravity circulation, or a combination of both. The recirculating pumps of forced-circulation generators must operate continuously while the generator is being fired. Steam boilers relying on natural circulation may require internal baffling when used for HTW generation. In scotch marine boilers, thermal shock may occur, caused by a sudden drop in the temperature of the return water or when the Δt exceeds




Fig. 4 Arrangement of Boiler Piping

40°F. Forced-circulation HTW generators are usually the once-through type and rely solely on pumps to achieve circulation. Depending on the design, internal orifices in the various circuits may be required to regulate the water flow rates in proportion to the heat absorption rates. Circulation must be maintained at all times while the generator is being fired, and the flow rate must never drop below the minimum indicated by the manufacturer.

Where gravity circulation steam boilers are used for HTW generation, the steam drum usually serves as an expansion vessel. In steam-pressurized forced-circulation HTW generators, a separate vessel is commonly used for expansion and for maintaining the steam pressure cushion. A separate vessel is always used when the system is cushioned by an inert gas or auxiliary steam. Proper internal circulation is essential in all types of boilers to prevent tube failures caused by overheating or unequal expansion.

In HTW systems, the generator is a steam boiler with an integral steam drum used for pressurization and for expansion of the water level. A dip pipe removes water below the water line (Figure 4) (Applegate 1958). This dip pipe should be installed so that it picks up water at or near the saturation temperature, without too many steam bubbles. If a pipe breaks somewhere in the system, the boiler must not empty to a point where heating surfaces are bared and a boiler explosion occurs. The same precautions must be taken with

the return pipe. If the return pipe is connected in the lower part of the boiler, a check valve should be placed in the connecting line to the boiler to preclude the danger of emptying the boiler.

When two or more such boilers supply a common system, the same steam pressure and water level must be maintained in each. Water and steam balance pipes are usually installed between the drums (Figure 5). These should be liberally sized. The following table shows recommended sizes:

Boiler Rating, million Btu/h	Balance Pipe Diameter, in.
2.5	3
5	3.5
10	4
15	5
20	6
30	8

A difference of only 0.25 psi in the system pressure between two boilers operated at 100 psig would cause a difference of 9 in. in the water level. The situation is further aggravated because an upset is not self-balancing. Rather, when too high a heat release in one of the boilers has caused the pressure to rise and the water level to fall in this boiler, the decrease in the flow of colder return water into it causes a further pressure rise, while the opposite happens in the other boiler. It is therefore important that the firing rates match the flow through each boiler at all times. Modern practice is to use either flooded HTW heaters with a single external pressurized expansion drum common to all the generators, or the combination of steam boilers and a direct-contact (cascade) heater.

Expansion and Pressurization

In addition to the information in Chapter 12, the following factors should be considered:

- The connection point of the expansion tank used for pressurization greatly affects the pressure distribution throughout the system and the avoidance of HTW flashing.
- Proper safety devices for high and low water levels and excessive pressures should be incorporated in the expansion tank and interlocked with combustion safety and water flow rate controls.

The following four fundamental methods, in which pressure in a given hydraulic system can be kept at a desired level, amplify the discussion in Chapter 12 (Blossom and Ziel 1959, National Academy of Sciences 1959).

1. **Elevating the storage tank** is a simple pressurization method, but because of the great heights required for the pressure encountered, it is generally impractical.




Fig. 5 Piping Connections for Two or More Boilers in HTW System Pressurized by Steam

2. **Steam pressurization** requires the use of an expansion vessel separate from the HTW generator. Because firing and flow rates can never be perfectly matched, some steam is always carried. Therefore, the vessel must be above the HTW generators and connected in the supply water line from the generator. This steam, supplemented by flashing of the water in the expansion vessel, provides the steam cushion that pressurizes the system.

The expansion vessel must be equipped with steam safety valves capable of relieving the steam generated by all the generators. The generators themselves are usually designed for a substantially higher working pressure than the expansion drum, and their safety relief valves are set for the higher pressure to minimize their lift requirement.

The basic HTW pumping arrangements can be either single-pump, in which one pump handles both the generator and system loads, or two-pump, in which one pump circulates high-temperature water through the generator and a second pump circulates high-temperature water through the system (see Figures 6 and 7). The circulating pump moves the water from the expansion vessel to the system and back to the generator. The vessel must be elevated to increase the net positive suction pressure to prevent cavitation or flashing in the pump suction. This arrangement is critical. A bypass from the HTW system return line to the pump suction helps prevent flashing. Cooler return water is then mixed with hotter water from the expansion vessel to give a resulting temperature below the corresponding saturation point in the vessel.

In the two-pump system, the boiler recirculation should always exceed the system circulation, because excessive cooling of the water in the drum by the cooler return water entering the drum, in case of overcirculation, can cause pressure loss and flashing in the distribution system. Backflow into the drum can be prevented by installing a check valve in the balance line from the drum to the boiler recirculating pumps. Higher cushion pressure may be maintained by auxiliary steam from a separate generator.




Fig. 6 HTW Piping for Combined (One-Pump) System (Steam Pressurized)

Sizing. Steam-pressurized vessels should be sized for a total volume V_T , which is the sum of the volume V_1 required for the steam space, the volume V_2 required for water expansion, and the volume V_3 required for sludge and reserve. An allowance of 20% of the sum of V_2 and V_3 is a reasonable estimate of the volume V_1 required for the steam space.

The volume V_2 required for water expansion is determined from the change in water volume from the minimum to the maximum operating temperatures of the complete cycle. It is not necessary to allow for expansion of the total water volume in the system from a cold initial start. It is necessary during a start-up period to bleed off the volume of water caused by expansion from the initial starting temperature to the lowest average operating temperature.

The volume V_3 for sludge and reserve varies greatly depending on the size and design of system and generator capacity. An allowance of 40% of the volume V_2 required for water expansion is a reasonable estimate of the volume required for V_3 .

3. **Nitrogen**, the most commonly used inert gas, is used for gas pressurization. Air is not recommended because the oxygen in air contributes to corrosion in the system.

The expansion vessel is connected as close as possible to the suction side of the HTW pump by a balance line. The inert gas used for pressurization is fed into the top of the cylinder, preferably through a manual fill connection using a reducing station connected to an inert gas cylinder. Locating the relief valve below the minimum water line is advantageous, because it is easier to keep it tightly sealed with water on the pressure side. If the valve is located above the water line, it is exposed to the inert gas of the system.

To reduce the area of contact between gas and water and the resulting absorption of gas into the water, the tank should be installed vertically. It should be located in the most suitable place in the central station. Similar to the steam-pressurized system, the pumping arrangements can be either one- or two-pump (see Figures 8 and 9).




Fig. 7 HTW Piping for Separate (Two-Pump) System (Steam Pressurized)

The ratings of fittings, valves, piping, and equipment are considered in determining the maximum system pressure. A minimum pressure of about 25 to 50 psi over the maximum saturation pressure can be used. The imposed additional pressure above the vapor pressure must be large enough to prevent steaming in the HTW generators at all times, even under conditions when flow and firing rates in generators operated in parallel, or flow and heat absorption in parallel circuits within a generator, are not evenly matched. This is critical, because gas-pressurized systems do not have steam separating means and safety valves to evacuate the steam generated.

The simplest type of gas-pressurization system uses a variable gas quantity with or without gas recovery (Figure 10) (National Academy of Sciences 1959). When the water rises, the inert gas is relieved from the expansion vessel and is wasted or recovered in a low-pressure gas receiver from which the gas compressor pumps it into a high-pressure receiver for storage. When the water level drops in the expansion vessel, the control cycle adds inert gas from bottles or from the high-pressure receiver to the expansion vessel to maintain the required pressure.

Gas wastage can significantly affect the operating cost. The gas recovery system should be analyzed based on the economics of each application. Gas recovery is generally more applicable to larger systems.

Sizing. The vessel should be sized for a total volume V_T , which is the sum of the volume V_1 required for pressurization, the volume V_2 required for water expansion, and the volume V_3 required for sludge and reserve.

Calculations made on the basis of pressure-volume variations following Boyle's Law are reasonably accurate, assuming that the tank




Fig. 8 Inert Gas Pressurization for One-Pump System




Fig. 9 Inert Gas Pressurization for Two-Pump System

operates at a relatively constant temperature. The minimum gas volume can be determined from the expansion volume V_2 and from the control range between the minimum tank pressure P_1 and the maximum tank pressure P_2 . The gas volume varies from the minimum V_1 to a maximum, which includes the water expansion volume V_2 .

The minimum gas volume V_1 can be obtained from

$$V_1 = P_1 V_2 / (P_2 - P_1)$$

where P_1 and P_2 are units of absolute pressure.

An allowance of 10% of the sum of V_1 and V_2 is a reasonable estimate of the sludge and reserve capacity V_3 . The volume V_2 required for water expansion should be limited to the actual expansion that occurs during operation through its minimum to maximum operating temperatures. It is necessary to bleed off water during a start-up cycle from a cold start. It is practicable on small systems (e.g., under 1,000,000 to 10,000,000 Btu/h) to size the expansion vessel for the total water expansion from the initial fill temperature.

4. Pump pressurization in its simplest form consists of a feed pump and a regulator valve. The pump operates continuously, introducing water from the makeup tank into the system. The pressure regulator valve bleeds continuously back into the makeup tank. This method is usually restricted to small process heating systems. However, it can be used to temporarily pressurize a larger system to avoid shutdown during inspection of the expansion tank.

In larger central HTW systems, pump pressurization is combined with a fixed-quantity gas compression tank that acts as a buffer. When the pressure rises above a preset value in the buffer tank, a control valve opens to relieve water from the balance line into the makeup storage tank. When the pressure falls below a preset second value, the feed pump is started automatically to pump water from the makeup tank back into the system. The buffer tank is designed to absorb only the limited expansion volume that is required for the pressure control system to function properly; it is usually small.

To prevent corrosion-causing elements, principally oxygen, from entering the HTW system, the makeup storage tank is usually closed and a low-pressure nitrogen cushion of 1 to 5 psig is maintained. The gas cushion is usually the variable gas quantity type with release to the atmosphere.




Fig. 10 Inert Gas Pressurization Using Variable Gas Quantity with Gas Recovery

Direct-Contact Heaters (Cascades)

High-temperature water can be obtained from direct-contact heaters in which steam from turbine exhaust, extraction, or steam boilers is mixed with return water from the system. The mixing takes place in the upper part of the heater where the water cascading from horizontal baffles comes in direct contact with steam (Hansen 1966). The basic systems are shown in [Figures 11 and 12](#).

The steam space in the upper part of the heater serves as the steam cushion for pressurizing the system. The lower part of the heater serves as the system's expansion tank. Where the water heater and the boiler operate under the same pressure, the surplus water is usually returned directly into the boiler through a pipe connecting the outlet of the high-temperature water-circulating pump to the boiler.

The cascade system is also applicable where both steam and HTW services are required (Hansen and Liddy 1958). Where heat and power production are combined, the direct-contact heater becomes the mixing condenser (Hansen and Perrisall 1960).

System Circulating Pumps

Forced-circulation boiler systems can be either one-pump or two-pump. These terms do not refer to the number of pumps but to the number of groups of pumps installed. In the one-pump system (see [Figure 6](#)), a single group of pumps assures both generator and distribution system circulation. In this system, both the distribution system and the generators are in series (Carter and Sturdevant 1958).




Fig. 11 Cascade HTW System




Fig. 12 Cascade HTW System Combined with Boiler Feedwater Preheating

However, to ensure the minimum flow through the boiler at all times, a bypass around the distribution system must be provided. The one-pump method usually applies only to systems in which the total friction pressure is relatively low, because the energy loss of available circulating pressure from throttling in the bypass at times of reduced flow requirements in the district can substantially increase the operating cost.

In the two-pump system (see Figure 7), an additional group of recirculating pumps is installed solely to provide circulation for the generators (Carter and Sturdevant 1958). One pump is often used for each generator to draw water from either the expansion drum or the system return and to pump it through the generator into the expansion drum. The system circulating pumps draw water from the expansion drum and circulate it through the distribution system only. The supply temperature to the distribution system can be varied by mixing water from the return into the supply on the pump suction side. Where zoning is required, several groups of pumps can be used with a different pressure and different temperature in each zone. The flow rate can also be varied without affecting the generator circulation and without using a system bypass.

In steam-pressurized systems, the circulating pump is installed in the supply line to maintain all parts of the distributing system at pressures exceeding boiler pressure. This minimizes the danger of flashing into steam.

It is common practice to install a mixing connection from the return to the pump suction that bypasses the HTW generator. This connection is used for start-up and for modulating the supply temperature; it should not be relied on for increasing the pressure at the pump inlet. Where it is impossible to provide the required submergence by proper design, a separate small-bore premixing line should be provided.

Hansen (1966) describes push-pull pumping, which divides the circulating pressure equally between two pumps in series. One is placed in the supply and is sized to overcome frictional resistance in the supply line of the heat distribution system. The second pump is placed in the return and is sized to overcome frictional resistance in the return. The expansion tank pressure is impressed on the system between the pumps. The HTW generator is either between the

pumps or in the supply line from the pumps to the distribution system (see Figure 13).

In the push-pull system, the pressures in the supply and the return mains are symmetrical in relation to a line representing the pressure imposed on the system by the pressurizing source (expansion tank). This pressure becomes the system pressure when the pumps are stopped. The heat supply to equipment or secondary circuits is controlled by two equal regulating valves, one on the inlet and the other on the outlet side, instead of the customary single valve on the leaving side. Both valves are operated in unison from a common controller; there are equal frictional resistances on both sides. Therefore, the pressure in the user circuits or equipment is maintained at all times halfway between the pressures in the supply and return mains. Because the halfway point is located on the symmetry line, the pressure in the user equipment or circuits is always equal to that of the pressurizing source (expansion tank) plus or minus static pressure caused by elevation differences. In other words, no system distribution pressure is reflected against the user circuit or equipment.

While the pressure in the supply system is higher than that of the expansion tank, the pressure in the return system, being symmetrical to the former, is lower. Therefore, the push-pull method is applicable only where the temperature in the return is always significantly lower than that in the supply. Otherwise, flashing could occur. This is critical and requires careful investigation of the temperature-pressure relationship at all points. The push-pull method is not applicable in reverse-return systems.

Push-pull pumping permits use of standard 125 psi fittings and equipment in many medium-temperature water (MTW) systems. Such systems, combined with secondary pumping, can be connected directly to low-temperature terminal equipment in the building heating system. Temperature drops normally obtainable only in HTW systems can be achieved with MTW. For example, 330°F water can be generated at 90 psig and distributed at less than 125 psig. Its temperature can be reduced to 200°F by secondary pumping. The pressure in the terminal equipment then is 90 psig and the MTW is returned to the primary system at 180°F. The temperature difference between supply and return in the primary MTW system is 150°F, which is comparable to that of an HTW system. In addition, conventional heat exchangers, expansion tanks, and water makeup equipment are eliminated from the secondary systems.

DISTRIBUTION PIPING DESIGN

Data for pipe friction are presented in Chapter 36 of the 2005 *ASHRAE Handbook—Fundamentals*. These pipe friction and fitting loss tables are for a 60°F water temperature. When applied to HTW systems, the values obtained are excessively high. The data should be used for preliminary pipe sizing only. Final pressure drop calculations should be made using the fundamental Darcy-Weisbach equation [Equation (1) in Chapter 36 of the 2005 *ASHRAE Handbook—Fundamentals*] in conjunction with friction factors, pipe roughness, and fitting loss coefficients presented in the section on Flow Analysis in Chapter 2 of the 2005 *ASHRAE Handbook—Fundamentals*.

The conventional conduit or tunnel distribution systems are used with similar techniques for installation (see Chapter 11). A small valved bypass connection between the supply and the return pipe should be installed at the end of long runs to maintain a slight circulation in the mains during periods of minimum or no demand.

All pipe, valves, and fittings used in HTW systems should comply with the requirements of ASME *Standard B-31.1, Power Piping*, and the *National Fuel Gas Code (NFPA 54/ANSI Z223.1)*. These codes state that hot-water systems should be designed for the highest pressure and temperature actually existing in the piping under normal operation. This pressure equals cushion pressure plus pump pressure plus static pressure. Schedule 40 steel pipe is appli-




Fig. 13 Typical HTW System with Push-Pull Pumping

cable to most HTW systems with welded steel fittings and steel valves. A minimum number of joints should be used. In many installations, all valves in the piping system are welded or brazed. Flange connections used at major equipment can be serrated, raised flange facing, or ring joint. It is desirable to have back-seating valves with special packing suitable for this service.

The ratings of valves, pipe, and fittings must be checked to determine the specific rating point for the given application. The pressure rating for a standard 300 psi steel valve operating at 400°F is 665 psi. Therefore, it is generally not necessary to use steel valves and fittings over 300 psi ratings in HTW systems.

Because high-temperature water is more penetrating than low-temperature water, leakage caused partly by capillary action should not be ignored because even a small amount of leakage vaporizes immediately. This slight leakage becomes noticeable only on the outside of the gland and stem of the valve where thin deposits of salt are left after evaporation. Avoid screwed joints and fittings in HTW systems. Pipe unions should not be used in place of flange connections, even for small-bore piping and equipment.

Individual heating equipment units should be installed with separate valves for shutoff. These should be readily accessible. If the unit is to be isolated for service, valves are needed in both the supply and return piping to the unit. Valve trim should be stainless steel or a similar alloy. Do not use brass and bronze.

High points in piping should have air vents for collecting and removing air, and low points should have provision for drainage. Loop-type expansion joints, in which the expansion is absorbed by deflection of the pipe loop, are preferable to the mechanical type. Mechanical expansion joints must be properly guided and anchored.

HEAT EXCHANGERS

Heat exchangers or converters commonly use steel shells with stainless steel, admiralty metal, or cupronickel tubes. Copper should not be used in HTW systems above 250°F. Material must be chosen carefully, considering the pressure-temperature characteristics of the particular system. All connections should be flanged or welded. On larger exchangers, water box-type construction is desirable to remove the tube bundle without breaking piping connections. Normally, HTW is circulated through the tubes, and because the heated water contains dissolved air, the baffles in the shell should be constructed of the same material as the tubes to control corrosion.

AIR HEATING COILS

In HTW systems over 400°F, coils should be cupronickel or all-steel construction. Below this point, other materials (e.g., red brass) can be used after determining their suitability for the temperatures involved. Coils in outdoor air connections need freeze protection by damper closure or fan shutdown controlled by a thermostat. It is also possible to set the control valve on the preheat coil to a minimum position. This protects against freezing, as long as there is no unbalance in the tube circuits where parallel paths of HTW flow exist. A better method is to provide constant flow through the coil and to control heat output with face and bypass dampers or by modulating the water temperature with a mixing pump.

SPACE HEATING EQUIPMENT

In industrial areas, space heating equipment can be operated with the available high-temperature water. Convectors and radiators may require water temperatures in the low- and medium-temperature range 120 to 180°F or 200 to 250°F, depending on their design pressure and proximity to the occupants. The water velocity through the heating equipment affects its capacity. This must be considered in selecting the equipment because, if a large water temperature drop is used, the circulation rate is reduced and, consequently, the flow

velocity may be reduced enough to appreciably lower the heat transfer rate.

Convectors, specially designed to provide low surface temperatures, are now available to operate with water temperatures from 300 to 400°F.

These high temperatures are suitable for direct use in radiant panel surfaces. Because radiant output is a fourth-power function of the surface temperature, the surface area requirements are reduced over low-temperature water systems. The surfaces can be flat panels consisting of a steel tube, usually 0.38 or 0.5 in., welded to sheet steel turned up at the edges for stiffening. Several variations are available. Steel pipe can also be used with an aluminum or similar reflector to reflect the heat downward and to prevent smudging the surfaces above the pipe.

INSTRUMENTATION AND CONTROLS

Pressure gages should be installed in the pump discharge and suction and at locations where pressure readings will assist operation and maintenance. Thermometers (preferably dial-type) or thermometer wells should be installed in the flow and return pipes, the pump discharge, and at any other points of major temperature change or where temperatures are important in operating the system. It is desirable to have thermometers and gages in the piping at the entrance to each building converter.

On steam-pressurized cycles, the temperature of the water leaving the generator should control the firing rate to the generator. A master pressure control operating from the steam pressure in the expansion vessel should be incorporated as a high-limit override. Inert gas-pressurized systems should be controlled from the generator discharge temperature. Combustion controls are discussed in detail in [Chapter 30](#).

In the water-tube generators most commonly used for HTW applications, the flow of water passes through the generator in seconds. The temperature controller must have a rapid response to maintain a reasonably uniform leaving water temperature. In steam-pressurized units, the temperature variation must not exceed the antiflash pressure margin. At 300°F, a 5°F temperature variation corresponds to a 5 psi variation in the vapor pressure. At 350°F, the same temperature variation results in a vapor pressure variation of 10 psi. At 400°F, the variation increases to 15 psi and at 450°F, to 22 psi. The permissible temperature swing must be reduced as the HTW temperature increases, or the pressure margin must be increased to avoid flashing.

Keep the controls simple. The rapid response through the generator makes it necessary to modulate the combustion rate on all systems with a capacity of over a few million Btu/h. In the smaller size range, this can be done by high/low firing. In large systems, particularly those used for central heating applications, full modulation of the combustion rate is desirable through at least 20% of full capacity. On/off burner control is generally not used in steam-pressurized cycles because the system loses pressurization during the off cycle, which can cause flashing and cavitation at the HTW pumps.

All generators should have separate safety controls to shut down the combustion apparatus when the system pressure or water temperature is high. HTW generators require a minimum water flow at all times to prevent tube failure. Means should be provided to measure the flow and to stop combustion if the flow falls below the minimum value recommended by the generator manufacturer. For inert gas-pressurized cycles, a low-pressure safety control should be included to shut down the combustion system if pressurization is lost. [Figure 14](#) shows the basic schematic control diagram for an HTW generator.

Valve selection and sizing are important because of relatively high temperature drops and smaller flows in HTW systems. The valve must be sized so that it is effective over its full range of travel. The valve and equipment must be sized to absorb, in the control valve at full flow, not less than half the available pressure difference




Fig. 14 Control Diagram for HTW Generator

between supply and return mains where the equipment is served. A valve with equal percentage flow characteristics is needed. Sometimes two small valves provide better control than one large valve. Stainless steel trim is recommended, and all valve body materials and packing should be suitable for high temperatures and pressures. The valve should have a close-off rating at least equal to the maximum pressure produced by the circulating pump. Generally, two-way valves are more desirable than three-way valves because of equal percentage flow characteristics and the smaller capacities available in two-way valves. Single-seated valves are preferable to double-seated valves because the latter do not close tightly.

Control valves are commonly located in the return lines from heat transfer units to reduce the valve operating temperature and to prevent plug erosion caused by high-temperature water flashing to steam at lower discharge pressure. A typical application is for controlling the temperature of water being heated in a heat exchanger where the heating medium is high-temperature water. The temperature-measuring element of the controller is installed on the secondary side and should be located where it can best detect changes to prevent overheating of outlet water. When the measuring element is located in the outlet pipe, there must be a continuous flow through the exchanger and past the element. The controller regulates the HTW supply to the primary side by means of the control valve in the HTW return. If the water leaving the exchanger is used for space heating, the set point of the thermostat in this water can be readjusted according to outdoor temperature.

Another typical application is to control a low- or medium-pressure steam generator, usually less than 50 psig, using high-temperature water as the heat source. In this application, a proportional pressure controller measures the steam pressure on the secondary side and positions the HTW control valve on the primary side to maintain the desired steam pressure. For general information on automatic controls, refer to Chapter 46 of the 2007 *ASHRAE Handbook—HVAC Applications*.

Where submergence is sufficient to prevent flashing in the *vena contracta*, control valves can be in the HTW supply instead of in the return to water heaters and steam generators (Figure 15). When used in conjunction with a check valve in the return, this arrangement shuts off the high-temperature water supply to the heat exchangers if a tube bundle leaks or ruptures.

WATER TREATMENT

Water treatment for HTW systems should be referred to a specialist. Oxygen introduced in makeup water immediately oxidizes steel at these temperatures, and over a period of time the corrosion




Fig. 15 Heat Exchanger Connections

can be substantial. Other impurities can also harm boiler tubes. Solids in impure water left by invisible vapor escaping at packings increase maintenance requirements. The condition of the water and the steel surfaces should be checked periodically in systems operating at these temperatures.

For further information, see Chapter 48 of the 2007 *ASHRAE Handbook—HVAC Applications*, especially the section on Water Heating Systems under Selection of Water Treatment.

HEAT STORAGE

The high heat storage capacity of water produces a flywheel effect in most HTW systems that evens out load fluctuations. Systems with normal peaks can obtain as much as 15% added capacity through such heat storage. Excessive peak and low loads of a cyclic nature can be eliminated by an HTW accumulator, based on the principle of stratification. Heat storage in an extensive system can sometimes be increased by bypassing water from the supply into the return at the end of the mains, or by raising the temperature of the returns during periods of low load.

SAFETY CONSIDERATIONS

A properly engineered and operated HTW system is safe and dependable. Careful selection and arrangement of components and materials are important. Piping must be designed and installed to prevent undue stress. When high-temperature water is released to atmospheric pressure, flashing takes place, which absorbs a large portion of the energy. Turbulent mixing of the liquid and vapor with room air reduces the temperature well below 212°F. With low mass flow rates, the temperature of the escaping mixture can fall to 125 to 140°F within a short distance, compared with the temperature of the discharge of a low-temperature water system, which remains essentially the same as the temperature of the working fluid (Hansen 1959, Armstrong and Harris 1966).

If large mass flow rates of HTW are released to atmospheric pressure in a confined space (e.g., rupture of a large pipe or vessel) a hazardous condition could exist, similar to that occurring with the rupture of a large steam main. Failures of this nature are rare if good engineering practice is followed in system design.

REFERENCES

- Applegate, G. 1958. British and European design and construction methods. *ASHRAE Journal* section, *Heating, Piping & Air Conditioning* 30(3):169.
- Armstrong, C.P. and W.S. Harris. 1966. Temperature distributions in steam and hot water jets simulating leaks. *ASHRAE Transactions* 72(1):147.
- Blossom, J.S. and P.H. Ziel. 1959. Pressurizing high-temperature water systems. *ASHRAE Journal* 1(11):47.
- Carter, C.A. and B.L. Sturdevant. 1958. Design of high temperature water systems for military installations. *ASHRAE Journal* section, *Heating, Piping & Air Conditioning* 29(2):109.

Hansen, E.G. 1959. Safety of high temperature hot water. *Actual Specifying Engineer* (July).

Hansen, E.G. 1966. Push-pull pumping permits use of MTW in building radiation. *Heating, Piping & Air Conditioning* 38(5):97.

Hansen, E.G. and W. Liddy. 1958. A flexible high pressure hot water and steam boiler plant. *Power* (May):109.

Hansen, E.G. and N.E. Perrisall. 1960. Turbo-generators supply steam for high-temperature water heating. *Air Conditioning, Heating and Ventilating* 32(6):90.

Keenan, J.H. and F.G. Keyes. 1936. *Thermodynamic properties of steam*. John Wiley & Sons, New York.

National Academy of Sciences. 1959. *High temperature water for heating and light process loads*. Federal Construction Council Technical Report no. 37. National Research Council Publication no. 753.

BIBLIOGRAPHY

ANSI/NFPA. 2006. *National fuel gas code*. ANSI Z223.1/NFPA 54-2006. National Fire Protection Association, Quincy, MA.

ASME. 2001. Power piping. *ANSI/ASME Standard B31.1-01*. American Society of Mechanical Engineers, New York.

[Related Commercial Resources](#)